

MINNESOTA DEPARTMENT OF HEALTH
SECTION OF DRINKING WATER PROTECTION

Report of Analytical Results



625 Robert St. N. St. Paul MN 55155
P.O. Box 64975 St. Paul MN 55164 - 0975

Final Report - Client Copy

The following are the results of your most recent sample analysis required for compliance with the Environmental Protection Agency's (EPA) Safe Drinking Water Rules. The results indicate the sample(s) collected was in compliance with Safe Drinking Water Rules. **This report pertains only to the contaminants which have a lab result listed below.** It may not address all regulated contaminants. These results must be kept in your files for a minimum of ten (10) years. If you have any questions, call 651/201-4700.

Program: HW Nontransient Noncommunity

System Name : **Star of the North Academy**
City : East Bethel

PWSID: 5020173

Laboratory : Minnesota Department of Health--Env. Laboratory

Date Collected	: 04/15/2024	Lab Sample #	: 24D0898-01
Date Received	: 04/15/2024	Field #	: KB0415C1
Date Analyzed	: 04/16/2024	Sample Type	: B
Collector Name	: Kathryn C. Bradley		
Collector ID	: 8111		
Sampling Site	: Well #1 EP		

Nitrate + Nitrite Nitrogen, Total: Less than .05 mg/L

Date Report Generated: 04/26/2024

STAR OF THE NORTH ACADEMY
C/O OPERATIONS COORDINATOR
1562 VIKING BOULEVARD NE
EAST BETHEL MN 55011